



Ref. Certif. No.

SE-118736

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded case circuit-breakers (MCCB)

Name and address of the applicant

ZHEJANG ETEK ELECTRICAL TECHNOLOGY CO., LTD
NO.288 Wei 17th Road, Yueqing Economic Development
zone, Yueqing, Wenzhou, ZheJiang Province, P.R. China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Same as applicant

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See page 2

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

EKM2-125, EKM2-125S, EKM2-125M

Additional information (if necessary may also be
reported on page 2)

☒ Additional Information on page 2

A sample of the product was tested and found
to be in conformity with

IEC 60947-2:2024

As shown in the Test Report Ref. No. which
forms part of this Certificate

2508B1173SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 17 February, 2026

intertek

Signature:

Anneli Averland Johansson

Ratings and principal characteristics

$U_e = 230V \sim (1P), 400V \sim (2P, 3P, 4P), 50/60Hz$;

$I_n = 63, 80, 100, 125A$; Cat: A, $U_i: 400V$, $U_{imp}: 6kV$

Instantaneous(fixed): $I_i = 10I_n \pm 20\%$, $I_i = 12I_n \pm 20\%$

EKM2-125: $I_{cs} = I_{cu} = 6kA$, EKM2-125S: $I_{cs} = I_{cu} = 3kA$, EKM2-125M: $I_{cs} = I_{cu} = 4,5kA$

reference temperature $+30^\circ C, +40^\circ C$

Date: 17 February, 2026

Signature:

A handwritten signature in blue ink, appearing to be 'André', is written over a light blue horizontal line.