



Ref. Certif. No.

SE-116532IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Time switch

Name and address of the applicant

Wenzhou ERH Technology Co., Ltd.
Jieda Road, Liushi, Yueqing, Wenzhou, Zhejiang, China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Same as applicant

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

Input: 85-250V~ 50/60Hz
Output: 250V~ 16(4)A

Trademark / Brand (if any)

ERH

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

TUL-181H, SUL-181H, TUL-181D, SUL-181D,
TUL-161H, SUL-161H, TUL-161D, SUL-161D

Additional information (if necessary may also be reported on page 2)

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60730-1:2013+A1+A2
IEC 60730-2-7:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

2501B1238SHA-001, 2501B1238SHA-002

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 12 May, 2025

intertek

Signature:

Hyden Li

Additional information

-10T50, class II, IP20, 5000 cycles (M, A), 1.B.R (for TUL-181H, TUL-181D, SUL-181H, SUL-161D); 1.B.S (for TUL-161H, TUL-161D, SUL-161H, SUL-161D), pollution degree 2, micro-disconnection, rated impulse voltage 4kV, overvoltage category III, PTI 175

There are 8 mechanical time switches for fixed installation, which are intended for DIN rail mounting. All the models are similar in structure and circuit design except for the differences listed below.

TUL-181H: 24H mechanical timer, with interval of 30 minutes, with additional NI-MH battery.

TUL-181D: Same as TUL-181H except with interval of 15 minutes.

TUL-161H: Same as TUL-181H except without additional NI-MH battery.

TUL-161D: Same as TUL-161H except with interval of 15 minutes.

SUL-181H: Same as TUL-181H except of model no.

SUL-181D: Same as TUL-181D except of model no.

SUL-161H: Same as TUL-161H except of model no.

SUL-161D: Same as TUL-161D except of model no.

Date: 12 May, 2025

Signature:

